


**Mani V. Venkatasubramanian**  
**Washington State University**

**Seyed Arash Sarmadi**  
**National Grid**

# Definitions


- System Mode – Inter-area Modes and Local Modes
- **Natural/System oscillations** – Oscillations from sources internal to the system
- **Forced oscillations** - Oscillations from sources external to the system

# Resonance in Physics



$$\left\{ \begin{array}{l} A = \frac{F_0/m}{\sqrt{(\omega_0^2 - \omega^2)^2 + (\omega\gamma)^2}} \\ \tan\delta = \frac{\omega\gamma}{\omega_0^2 - \omega^2} \end{array} \right.$$


poorly damped



## Forced Oscillations in WECC


- Many forced oscillations observed.
- **System modes keep getting excited by forced oscillations**
- Sources point to hydro units/controls...
- Oscillations at 0.4 Hz, 0.5 Hz, 0.6 Hz, 0.7 Hz, 0.8 Hz, 1.12 Hz... 2 Hz...
- Detection? Impact on nearby system modes?
- Resonance possible ?

# Resonance in Kundur Test System







- When does resonance occur?
- When is resonance **severe** versus **mild**?
- Sensitivity to forced oscillation frequency, location, system mode damping, and local versus inter-area mode.
- Recent paper in IEEE Trans. Power Systems

# Poorly damped case




- Inter-area mode 0.56 Hz damping ratio at 2%.
- 35 MW forced oscillation in the middle of the system
- Tie-line oscillations of 74 MW (0.53 Hz), 200 MW (0.56 Hz) and 70 MW (0.59 Hz) show strong resonance effect.

# Medium damped case



- Inter-area mode 0.56 Hz damping ratio at 5%.
- Tie-line oscillations of 65 MW (0.53 Hz), 90 MW (0.56 Hz) and 56 MW (0.59 Hz) show resonance effect.

# Well damped case




- Inter-area mode 0.56 Hz damping ratio at 10%.
- Tie-line oscillations of 53 MW (0.53 Hz), 58 MW (0.56 Hz) and 50 MW (0.59 Hz) show low resonance effect.




# Mode Shapes for Resonant Case

System Mode




Forced Oscillation



- SSI- Covariance can estimate system mode and forced oscillation *simultaneously*.
- Mode shape magnitude not dominant at source of forced oscillation for resonant case

# Sensitivity to location



FO Bus	Tie-line MW Osc
1	429
2	361
3	477
4	442
5	390
6	262
7	194
8	203
9	313
10	397
11	449


- Inter-area mode 0.56 Hz damping ratio at 2%. Forced Oscillation (FO) at 0.56 Hz.
- Largest Tie-line oscillations when FO at distant ends.

# Resonance - Linear Phenomenon

<b>FO MW</b>	<b>Tie-line MW Osc</b>
<b>2</b>	<b>20</b>
<b>10</b>	<b>95</b>
<b>20</b>	<b>203</b>
<b>40</b>	<b>427</b>
<b>100</b>	<b>516</b>

- **Inter-area mode 0.56 Hz damping ratio at 2%. Forced Oscillation (FO) at 0.56 Hz at Bus 8.**
- **Tie-line Oscillation MW grows linearly with respect to Forced Oscillation MW up to a point.**

# High Resonance Case



**35 MW Forced Oscillation can lead to 480 MW Tie-line oscillations when FO freq close to system mode freq and system mode at 2% damping ratio.**

**Tie-line oscillations can be about 400 MW if FO near the sending end; 480 MW if FO near the receiving end;**

# Resonance with Inter-area Mode

**Resonance effect high** when:

- Forced Oscillation freq near System Mode freq
- System Mode poorly damped
- Forced Oscillation location near the two distant ends (strong participation) of the System Mode


**Resonance effect medium** when:

- Some conditions hold

**Resonance effect small** when:

- None of the conditions holds


# FDD Mode Shapes on June 13, 2013




**Case 1**  
**0.38 Hz at**  
**0.6% Damping Ratio**

**Case 2**  
**0.38 Hz at**  
**12% Damping Ratio**

# PMU Apparent Power Signals on PMU 1




**Case 1**  
**0.37 Hz at**  
**0.6% Damping Ratio**



**Case 2**  
**0.4 Hz at**  
**Near 8% Damping Ratio**


# No resonance on June 13, 2013



**a**

Case 1  
0.37 Hz


Forced Oscillation



**b**

Case 1  
0.4 Hz at


15% Damping Ratio



**c**

Case 2  
0.4 Hz at

14% Damping Ratio




Resonance effect **low** because system mode well-damped and FO location near the center of the mode.

No tie-line oscillations from 10 MW forced oscillation.




# Medium Resonance on November 29, 2005



- 20 MW 0.27 Hz Forced Oscillation in Alberta Canada.
- System mode 0.26 Hz at around 7% damping.
- 200 MW Oscillations on California-Oregon Inter-tie.
- **Resonance Amplification Factor = 10.**
- Recent IEEE Trans. paper


Thanks to Greg Stults (BPA) and Jim Burns (BPA)

# Medium resonance on November 29, 2005



Resonance effect **medium** because system mode **well-damped** (7%) and FO location near **one end** of the mode. **200 MW** tie-line oscillations from **20 MW** forced oscillation. (Recent IEEE Trans. Paper)

# Medium Resonance on November 29, 2005



- System mode 0.26 Hz and Forced Oscillation at 0.27 Hz
- Forced Oscillation source near Sending End
- System Mode Well-damped at 7%
- Two out of three conditions were true.
- Resonance Amplification Factor = 10.
- Warning for the future.

# Summary

- **Forced Oscillations are problematic...**
- **Nov 29, 2005 Alberta event - documented instance of resonance between forced oscillation and inter-area mode.**
- **Resonance – risk for operational reliability of the grid**
- **Source location tricky in case of resonance**
- **MW output may not be the largest at the oscillation source due to nature of resonance.**
- **Mode shape angle may be a better indicator**
- **Further research needed**